Certificado de Conformidad

Por medio del certificado de producto número / *By the product certificate number* **Nº 2622/0287-A-CER**

Emitido a / *Issued to:*

Titular del certificado / *License holder:* **FOXESS CO., LTD.**
No.939, Jinhai Third Road, New Airport Industry Area, Longwan District, Wenzhou, Zhejiang, China

Marca / *Trademark:*

Fábrica / *Manufacturer:* **FOXESS CO., LTD.**
No.939, Jinhai Third Road, New Airport Industry Area, Longwan District, Wenzhou, Zhejiang, China

Se certifica que el product / *It is certified that the product:*
Tipo de aparato / *Type of product:* **PV Grid-tied Inverter**

Modelos / *Models:*	**S700-G2 / S1000-G2 / S1500-G2 / S2000-G2 / S2500-G2 / S3000-G2 / S3300-G2**	
Datos técnicos / *Rated characteristics:*	**Potencia nominal** / *Rated Power*	**Ver página 2** / *See page 2*
	Tensión nominal / *Rated Voltage*	**Ver página 2** / *See page 2*
	Frecuencia nominal / *Rated Frequency*	**50 Hz**
	Versión Firmware / *Firmware version*	**Master: V1.22, Slave: V0.14, ARM: V0.29**
	Número de fases / *Number of phases*	**Monofásico** / *Single Phase*
	Transformador de aislamiento / *Isolation transformer*	**No** / *No*

Está en cumplimiento con la norma de ensayos / *Is in compliance with the test standard:*

- **UNE 217002: 2020** Inversores para conexión a la red de distribución. Ensayos de los requisitos de inyección de corriente continua a la red, generación de sobretensiones y sistema de detección de funcionamiento en isla

Está en cumplimiento con los requisitos de la norma y regulación / *Is in compliance with the requirements of standard and regulation:*

- **IEC 62116** "Utility-interconnected photovoltaic inverters-Test procedure of islanding prevention measures"
- **Anexo I, apartado 2.3.6 y 5.3 de la Orden Ministerial TED/749/2020**, de 16 de julio, por la que se establecen los requisitos técnicos para la conexión a la red necesarios para la implementación de los códigos de red de conexión.

El equipo antes mencionado está certificado conforme con el procedimiento interno de SGS PE.T-ECPE-23 de acuerdo con los requisitos de la norma UNE-EN ISO/IEC 17065. / *The above-mentioned generating unit is certified according to the SGS internal procedure PE.T-ECPE-23 based on the requirements of the UNE-EN ISO / IEC 17065.*

Este certificado se emite por vez primera: 24 de junio de 2022. / *This certificate is first issued on 24th of June 2022.*
Este certificado es válido hasta: 24 de junio 2027. / *This certificate is valid until the 24th of June 2027.*

Madrid, 24 de junio de 2022.

Daniel Arranz Muñiz
Certification Manager

Lista completa de referencias con las características nominales de los productos certificados / *Full list of product references and nominal characteristics:*

Model	S700-G2	S1000-G2	S1500-G2	S2000-G2	S2500-G2	S3000-G2	**S3300-G2**
Input (DC)							
Max. input current	14 A						
Max.DC Voltage	500 V						
MPPT Voltage Range	50~480 V						
Output (AC)							
Rated AC Output Power	700 W	1000 W	1500 W	2000 W	2500 W	3000 W	3300 W
Max AC Output Apparent Power	800 VA	1100 VA	1650 VA	2200 VA	2750 VA	3300 VA	3300 VA
Nominal Grid Voltage	220 / 230 / 240 V						
Nominal Frequency	50/60 Hz						